



DECLARATION FOR GAD approval

Declare that for the following central heating boilers Intergas Calefacción sucursal en España

Kombi Kompakt HR 28/24, Kombi Kompakt HR 36/30 and Prestige

- The installation and user's instructions, type plate and packaging inscriptions are translated into the official language of the country of destination, taking into account the national installation regulations of the country concerned;
- For appliances, not meant for installation by a professional installer (e.g. leisure appliances), the manufacturer has investigated which national and regional regulations are in force and that these regulations (additions / restrictions) are implemented in the installation- and user instructions
- Marking, required by the standard is clearly legible and durable
- The materials used in these appliances have been so selected that safety and proper performance of these appliances is ensured and that the materials are resistant to the chemical, mechanical and thermal influences to which the appliances will be exposed during their expected service life;
- No asbestos has been used;
- For gas-carrying parts no soft-soldered joints are applied;
- Settings that should not be altered have been sealed;
- The components of the appliance which may come into contact with food and/or water used for sanitary purposes must not impair the quality of this food and/or water.
- Connections to the gas supply (line/bottle etc.) shall be country specific. (nozzles, ISO, etc.)

Electrical aspects:

- Wood, cotton, silk, ordinary paper, hygroscopic material is not used as insulation, unless impregnated; (EN 60335-1 clause 22.21)
- Oils containing polychlorinated biphenyl (PCB) are not used; (EN 60335-1 clause 22.23)
- The electrical equipment of the appliance, which is not covered in the GAD approval, complies with the requirements of the Low-Voltage Directive (2006/95/EC). (In particular the standards EN 60335-1 and EN 60335-2-102)

For modifications to type approval:

- For this appliance the manufacturer has investigated the most recent applicable standards (new as well as updated standards) and declares that no modification or assessment of the appliance is necessary, other than assessed in the past (if applicable) and/or are assessed during this modification.

On behalf of Intergas Verwarming BV.

Name:

H. Bosscher

Function:

Directeur

Date:

12.05.2011

Intergas Verwarming BV

De Holwert 1 Telefoon +31 (0)524 - 51 23 45
 7741 KC Coevorden Fax +31 (0)524 - 51 68 68
 Postbus 6 Internet www.intergasverwarming.nl
 7740 AA Coevorden E-mail info@intergasverwarming.nl

Handelsregister Meppel nr. 04-068371 ING Bank, N.V., a.o. Frankfurt am Main
 ING Bank Coevorden 65.87.13.051 Konto 25605312
 IBAN: NL27INGB0658713051 BLZ 500 210 00
 IBAN: DE98500210000025605312