

Number	67672	Replaces	64889
Issued	23-04-2012	Scope	EN 483
Report number	170527/17		
PIN	0063AR3527	Contract number	E 8690

Kiwa hereby declares that the examined **Central Heating Boilers** of the following types


**Prestige
Kombi Kompakt HR 24
Kombi Kompakt HR 28/24
Kombi Kompakt HR 36/30**

supplied by **Intergas Calderas de Calefacción S.L.,
San Pedro de Alcántara (Málaga), Spain,**

meet the NO_x-emission requirements specified in the **EN 483:1999 Gas-fired central heating boilers**, type C boilers of nominal heat input not exceeding 70 kW and consequently may carry the following symbol:

NO_x Class: 5

This declaration was drawn up in Apeldoorn, The Netherlands on **23-04-2012** and remains valid until the construction of the products is changed.



Bouke Meekma
Kiwa